## § 96.303

- (2) By United States Postal Service; or
- (3) By other means of dispatch or transmission and delivery. Compliance with any "submission" or "service" deadline shall be determined by the date of dispatch, transmission, or mailing and not the date of receipt.

Title V operating permit means a permit issued under title V of the Clean Air Act and part 70 or part 71 of this chapter.

Title V operating permit regulations means the regulations that the Administrator has approved or issued as meeting the requirements of title V of the Clean Air Act and part 70 or 71 of this chapter.

Ton means 2,000 pounds. For the purpose of determining compliance with the CAIR  $NO_{\rm X}$  Ozone Season emissions limitation, total tons of nitrogen oxides emissions for a control period shall be calculated as the sum of all recorded hourly emissions (or the mass equivalent of the recorded hourly emission rates) in accordance with subpart HHHH of this part, but with any remaining fraction of a ton equal to or greater than 0.50 tons deemed to equal one ton and any remaining fraction of a ton less than 0.50 tons deemed to equal zero tons.

Topping-cycle cogeneration unit means a cogeneration unit in which the energy input to the unit is first used to produce useful power, including electricity, and at least some of the reject heat from the electricity production is then used to provide useful thermal energy

Total energy input means, with regard to a cogeneration unit, total energy of all forms supplied to the cogeneration unit, excluding energy produced by the cogeneration unit itself. Each form of energy supplied shall be measured by the lower heating value of that form of energy calculated as follows:

LHV = HHV - 10.55(W + 9H)

Where:

LHV = lower heating value of fuel in Btu/lb, HHV = higher heating value of fuel in Btu/lb, W = Weight % of moisture in fuel, and H = Weight % of hydrogen in fuel.

Total energy output means, with regard to a cogeneration unit, the sum of

useful power and useful thermal energy produced by the cogeneration unit.

Unit means a stationary, fossil-fuel-fired boiler or combustion turbine or other stationary, fossil-fuel-fired combustion device.

Unit operating day means a calendar day in which a unit combusts any fuel.

Unit operating hour or hour of unit operation means an hour in which a unit combusts any fuel.

Useful power means, with regard to a cogeneration unit, electricity or mechanical energy made available for use, excluding any such energy used in the power production process (which process includes, but is not limited to, any on-site processing or treatment of fuel combusted at the unit and any on-site emission controls).

Useful thermal energy means, with regard to a cogeneration unit, thermal energy that is:

- (1) Made available to an industrial or commercial process (not a power production process), excluding any heat contained in condensate return or makeup water;
- (2) Used in a heating application (e.g., space heating or domestic hot water heating); or
- (3) Used in a space cooling application (i.e., thermal energy used by an absorption chiller).

Utility power distribution system means the portion of an electricity grid owned or operated by a utility and dedicated to delivering electricity to customers.

[70 FR 25382, May 12, 2005, as amended at 71 FR 25390, Apr. 28, 2006; 71 FR 74794, Dec. 13, 2006; 72 FR 59206, Oct. 19, 2007]

## § 96.303 Measurements, abbreviations, and acronyms.

Measurements, abbreviations, and acronyms used in this subpart and subparts BBBB through IIII are defined as follows:

Btu—British thermal unit

CO<sub>2</sub>—carbon dioxide

H<sub>2</sub>O—water

Hg—mercury

hr—hour

kW-kilowatt electrical

kWh—kilowatt hour

lb—pound

mmBtu—million Btu

MWe-megawatt electrical

MWh-megawatt hour

## **Environmental Protection Agency**

 $NO_X$ —nitrogen oxides  $O_2$ —oxygen ppm—parts per million scfh—standard cubic feet per hour  $SO_2$ —sulfur dioxide yr—year

[71 FR 25392, Apr. 28, 2006]

## § 96.304 Applicability.

- (a) Except as provided in paragraph (b) of this section:
- (1) The following units in a State shall be CAIR  $NO_X$  Ozone Season units, and any source that includes one or more such units shall be a CAIR  $NO_X$  Ozone Season source, subject to the requirements of this subpart and subparts BBBB through HHHH of this part: any stationary, fossil-fuel-fired boiler or stationary, fossil-fuel-fired combustion turbine serving at any time, since the later of November 15, 1990 or the start-up of the unit's combustion chamber, a generator with nameplate capacity of more than 25 MWe producing electricity for sale.
- (2) If a stationary boiler or stationary combustion turbine that, under paragraph (a)(1) of this section, is not a CAIR  $NO_X$  Ozone Season unit begins to combust fossil fuel or to serve a generator with nameplate capacity of more than 25 MWe producing electricity for sale, the unit shall become a CAIR  $NO_X$  Ozone Season unit as provided in paragraph (a)(1) of this section on the first date on which it both combusts fossil fuel and serves such generator.
- (b) The units in a State that meet the requirements set forth in paragraph (b)(1)(i), (b)(2)(i), or (b)(2)(ii) of this section shall not be CAIR  $NO_X$  Ozone Season units:
- (1)(i) Any unit that is a CAIR  $NO_X$  Ozone Season unit under paragraph (a)(1) or (2) of this section:
- (A) Qualifying as a cogeneration unit during the 12-month period starting on the date the unit first produces electricity and continuing to qualify as a cogeneration unit; and
- (B) Not serving at any time, since the later of November 15, 1990 or the startup of the unit's combustion chamber, a generator with nameplate capacity of more than 25 MWe supplying in any calendar year more than one-third of the unit's potential electric output capacity or 219,000 MWh, whichever is

greater, to any utility power distribution system for sale.

- (ii) If a unit qualifies as a cogeneration unit during the 12-month period starting on the date the unit first produces electricity and meets the requirements of paragraphs (b)(1)(i) of this section for at least one calendar year, but subsequently no longer meets all such requirements, the unit shall become a CAIR NO<sub>X</sub> Ozone Season unit starting on the earlier of January 1 after the first calendar year during which the unit first no longer qualifies as a cogeneration unit or January 1 after the first calendar year during which the unit no longer meets the requirements of paragraph (b)(1)(i)(B) of this section.
- (2)(i) Any unit that is a CAIR  $NO_X$  Ozone Season unit under paragraph (a)(1) or (2) of this section commencing operation before January 1, 1985:
- (A) Qualifying as a solid waste incineration unit; and
- (B) With an average annual fuel consumption of non-fossil fuel for 1985–1987 exceeding 80 percent (on a Btu basis) and an average annual fuel consumption of non-fossil fuel for any 3 consecutive calendar years after 1990 exceeding 80 percent (on a Btu basis).
- (ii) Any unit that is a CAIR  $NO_X$  Ozone Season unit under paragraph (a)(1) or (2) of this section commencing operation on or after January 1, 1985:
- (A) Qualifying as a solid waste incineration unit; and
- (B) With an average annual fuel consumption of non-fossil fuel for the first 3 calendar years of operation exceeding 80 percent (on a Btu basis) and an average annual fuel consumption of non-fossil fuel for any 3 consecutive calendar years after 1990 exceeding 80 percent (on a Btu basis).
- (iii) If a unit qualifies as a solid waste incineration unit and meets the requirements of paragraph (b)(2)(i) or (ii) of this section for at least 3 consecutive calendar years, but subsequently no longer meets all such requirements, the unit shall become a CAIR  $NO_X$  Ozone Season unit starting on the earlier of January 1 after the first calendar year during which the unit first no longer qualifies as a solid waste incineration unit or January 1 after the first 3 consecutive calendar